



Job #139968453

GenerX Generator Service Form (Appt 139968453-1)

Customer Name

Jongsma, Johan and Tatyana

Generator Location

Jongsma, Johan & Tatyana

Customer Email

TJ@Jongsma.me

Customer Phone Number

(727) 225-2475

Technician

Eduardo Rivera

Service Advisor Name

Emily Bailiff

Service Advisor Email

Emily.b@fixmygen.com

Generator Condition

General picture of Generator and immediate surroundings



Activation Date

Na

Transfer Switch Condition

General picture of Transfer Switch and immediate surroundings




ATS Data Tag

ATS Data Tag



Serial Number of Generator

Serial Number



Run Hours

Picture of Controller



Run Hours

Text

141.8

Fuel Supply

Picture of propane level/gauge or Natural Gas



Battery Condition and Test

Picture of Battery area and picture of battery test results.



Fault Code (if applicable)

Picture of Controller



Picture of Breaker

Transfer Switch Upon Leaving

Comments/Recommended Repairs (CUSTOMER FACING)

Oldsmar service- Eduardo and Ryan for AMS + repairs: Techs completed the roof insulation repair, removing the enclosure top and resealing the insulation onto the top. Completed AMS + IOA, replacing oil, oil filter, air filter, and added IOA. Repairs to the starter motor and relay incomplete, new motor has different specs and needs different hardware to properly install it. Return trip: installed the new starter motor and contactor, using proper hardware and confirming good startup. Performed transfer test successfully, running 10 minutes without issue and measuring 241vac/ 60hz. Generator is producing good voltage and performing within specs. Office has cc info.