



Job #137510265

## GenerX Generator Service Form (Appt 137510265-1)

---

**Customer Name**

Jongsma, Johan and Tatyana

---

**Generator Location**

Jongsma, Johan & Tatyana

---

**Customer Email**

TJ@Jongsma.me

---

**Customer Phone Number**

(727) 225-2475

---

**Technician**

Eduardo Rivera

---

**Service Advisor Name**

Emily Bailiff

---

**Service Advisor Email**

emily.b@fixmygen.com

---

**Generator Condition**

General picture of Generator and immediate surroundings



---

**Activation Date**

07/10/2014



---

## Run Hours

Picture of Controller



---

## Run Hours

Text

140.4

---

## Fuel Supply

Picture of propane level/gauge or Natural Gas



---

## Battery Condition and Test

Picture of Battery area and picture of battery test results.



---

**Fault Code (if applicable)**

Picture of Controller



---

**Picture of Breaker**

---

**Transfer Switch Upon Leaving**

---

**Comments/Recommended Repairs (CUSTOMER FACING)**

Oldsmar service-Eduardo for Diag: customer informed tech of startup issues during a recent outage, noting a fault for rpm loss. Generator is able to startup manually and produce good voltage, receiving proper 12vdc to the starter. Testing indicates the starter motor is intermittent failing. Recommend a replacing the starter motor and connecting contact + maintenance. Inspected the radiator, noting that while intact, signs of wear and tear are present. Customer would like to hold off any radiator repairs at this time. Generator set to auto and ready to run. Office has cc info.